



rfo-sfps-surat@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOSRT/2024/00071078

Date: 18/08/2026

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOSRT/2024/00071078/R2

Building Occupancy/Category: Educational (non-residential)

To,

PANDEY LALBIHARI SHUBHKARAN
451, 452, 555 KOSMANDI ANKLESHWAR ANKLESHWAR Bharuch 393001
Fire Region: Surat RFO
Mobile No: 9825044518 Email ID: sia.ank@gmail.com

We have received Application No. 2026/00212890 dated 05/08/2026 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCRe) for the building/premise VIDHYALAY SANATAN INTERNATIONAL ACADEMY (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: ANKLESHWAR
5. Name of Block(s): VIDHYALAY SANATAN INTERNATIONAL ACADEMY

The building/premise was inspected on 18/08/2026 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 17/08/2026 11:02:22 AM
2. Six monthly inspection was done on 17/08/2026 11:14:30 AM

The Fire Safety Certificate is renewed for a period of two (2) years upto 18/08/2028 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated: 18/08/2026 12:36:53 PM



Digitally Verified

Digitally verified by: Sejalben Jayprakash Joshi
Fire Safety Officer - Advance (FSO-A)
2021/000382
Reviewed by : RFO Surat
Date: 18/08/2026
Time: 12:54 PM



FSCA/O/RFOSRT/2024/00071078/R2

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.

PRINCIPAL
SANATAN INTERNATIONAL ACADEMY
Near Kapodra Patiya, Valia Road,
Kosamdi, Ankleshwar - 01