

Gujarat Water Supply and Sewerage Board

Phone No : 9978443265

Email : ankdee@gmail.com



Office of the Deputy Ex. Engineer,
Public Health San. Sub Division, Ankleshwar
Near Hasti Talav, Ankleshwar - 393 001

No. PB /Ankleshwar /Drinking Water / 377


Date: 06/08/2026

TO WHOME IT MAY CONCERN

on the basis of Water Test Report of Taluka Lab Ankleshwar It is certified that the Sanatan International Academy has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms of the Central Govt.

This certificate is valid till Date. 06.08.2027

To,
Sanatan International Academy
Valia Road, Kapodra Patiya,
Kosamdi, Ta. Ankleshwar


Deputy Executive Engineer
P.H. San. Sub Division,
Ankleshwar

Taluka Laboratory, Ankleshwar
Gujarat Water Supply & Sewerage
Board Near Hasti Talav, Opp Geeta
R.O. Plant, Navi Nagari Road,
Ankleshwar-393001
Dist-Bharuch



tlankleshwar@gmail.com

તાલુકા પ્રયોગશાળા અંકલેશ્વર
ગુ. પા. પુ. અને ગ.વ્ય. બોર્ડ,
હસ્તી તળાવ પાસે, ગીતા ઓપરેશનની
સામે, નવી નગરી રોડ,
અંકલેશ્વર-૩૯૩૦૦૧

TL7.8/F-01



NABL
Accreditation
Certificate No:-
NABL-DWT-01465

Name & Address of Customer:-

Sanatan International Academy
Valla Road, Kapodra Patiya,
Kosamdi, Ankleshwar
Dist-Bharuch

Customer Reference No. :

SIA/883/dt.01.08.20
26

Sample Submitted by :

Senders

Date of Sample Receipt :

03/08/2026

Analysis Starting Date :

04/08/2026

Analysis completion Date :

04/08/2026

ULR No

Discipline :

Chemical Testing, Group Water

Test Report No:

1416/2026-27

Date of Issue :

05/08/2026

Sample ID :

TACW-1416/08-2026

Mode of Sample :

Sanitation

Main Source :

R.O Water

Source :

Location :

At Sender Address

Village :

Kosamdi

Habitation :

Kosamdi

Taluka :

Ankleshwar

District :

Bharuch

Latitude :

--

Longitude :

--

Kindly find herewith the Analytical Results.


Sample Type :

Drinking Water

Sr. No.	Parameter	Unit	IS-10500:2012 (2nd Revision)		Reference Method :	Analytical Value
			Requirement (Acceptable Limit) Max.	Permissible Limit in the Absence of Alternate Source Max.		
1	Colour	Hazen	5	15	APHA (24th Ed.2017). Method: 2120 C	5.00
2	Odour	-	Agreeable	Agreeable	IS 3025 (Part 5) - 2018 (Second Revision)	Agreeable
3	Taste	-	Agreeable	Agreeable	IS 3025 (Part 5) - 1984 (Reaffirmed 2017)	Agreeable
4	Turbidity	NTU	1	5	APHA (24th Ed.2017). Method: 2130 B	0.00
5	pH at 25°C	-	6.5 to 8.5	No relaxation	APHA (24th Ed.2017) Method: 4500 H ⁺ B	8.48
6	Total Dissolved Solids	mg/l	500	2000	APHA (24th Ed.2017) Method: 2540 C	247
7	Total Hardness(as CaCO ₃)	mg/l	200	600	APHA (24th Ed.2017) Method: 2340 C	247
8	Calcium (as Ca ²⁺)	mg/l	75	200	APHA (24th Ed.2017) Method: 3500 Ca ²⁺ B	27
9	Magnesium (as Mg ²⁺)	mg/l	30	100	APHA (24th Ed.2017) Method: 3500-Mg ²⁺ B	35
10	Chloride (as Cl ⁻)	mg/l	250	1000	APHA (24th Ed.2017) Method: 4500-Cl ⁻ B	28
11	Sulphate (as SO ₄ ²⁻)	mg/l	200	400	APHA (24th Ed.2017) Method: 4500-SO ₄ ²⁻ E	28.78
12	Nitrate (as NO ₃ ⁻)	mg/l	45	No relaxation	APHA (24th Ed.2017) Method: 4500-NO ₃ ⁻ B	-
13	Fluoride (as F ⁻)	mg/l	1.00	1.50	APHA (24th Ed.2017) Method: 4500-F ⁻ C	0.07
14	Total Alkalinity (as CaCO ₃)	mg/l	200	600	APHA (24th Ed.2017) Method: 2320 B	40

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.



End of the Test Report

Authorized Signatory

LABORATORY INCHARGE,
TALUKA LABORATORY,
G.W.S. & S. BOARD,
ANKLESHWAR

PRINCIPAL
SANATAN INTERNATIONAL ACADEMY
Near Kapodra Patiya, Valia Road,
Kosamdi, Ankleshwar - 01



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Name & Address

Sanatan International Academy
Valia Road, Kapodra Patiya,
Kosamdi, Ankleshwar

Sender's Ref No SIA/883/dt.01.08.2026

Ref Date 03-Aug-26

Date & Time of Commencing Examination 03-Aug-26

Sample collected by : Senders

BW No.	TABW 1350
Date of Collection	3-Aug-26
Date of Arrival at Lab.	3-Aug-26
Source of Water Sample	R O Water At Sender Address
Village	Kosamdi
Habitation	Kosamdi
Taluka	Ankleshwar
District	Bharuch
APHA, AWWA, 9221-D Presence - Absence Coliform Test, @ 37° C	A
APHA, AWWA, 9221-F Presence - Absence E-Coli Test, @ 37° C	
MPN of coliform per 100 ml of sample at 37° C	<1
MPN of Faecal coliform per 100 ml of sample at 44° C	<1
Free Chlorine (PPM)	Nil
OPINION FOR POTABILITY :	FIT

Important Note:-

1) '>=' Indicates greater than or equal to, 2) '<' Indicates less than

NOTE : Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Revision.

@ All Water Intended for Drinking -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

@ Treated Water Entering the Distribution system & Treated Water in the Distribution system -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.


(b) Total coliform bacteria shall not be detectable in any 100ml sample.

@ 0.2ppm Free Residual Chlorine at consumer end is recommended.

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.

2) This Report should not be taken as a basis to getting license from any Government authority.

3) After Collection of Bact. Sample, it must be preserved at 4°C and submitted to laboratory within 24hrs



PRINCIPAL
SANATAN INTERNATIONAL ACADEMY
Near Kapodra Patiya, Valia Road,
Kosamdi, Ankleshwar - 01

Authorised Signatory

LABORATORY INCHARGE
TALUKA LABORATORY
G.W.S. & S. BOARD
ANKLESHWAR